



GEOPROGRAM Sp. z o.o.
ul. Fordońska 110
85-739 Bydgoszcz

ZAŁĄCZNIK 8

ZESTAWIENIE WYNIKÓW BADAŃ LABORATORYJNYCH

Warstwa	Próba	Rodzaj gruntu		Barwa	Walczki	CaCO ₃	W _n	W _p	W _L	I _p	I _L	I _c	τ _{Tv}	ρ	I _z	k _{USBSC}	k _{Hazen}	U	M ₀	M
		PN-86/B02480	PN-EN ISO 14688 1				[%]	[%]	[%]	[%]	[-]	[-]	[kPa]	[g/cm ³]	[%]	[m/s]	[m/s]	[-]	[kPa]	[kPa]
I	o3_2,0	Pd	fSa	beżowy		+	11,6%									3,01E-05			2,57	
II	o4_3,0	Ps	mSa	beżowy		+	16,1%									1,81E-04	6,80E-04		1,97	
IV	o1_9,0	Iπ	Cl	szary	2/1*	+	19,2%	19,9%	60,9%	41,0%	-0,02	1,02	215							
IV	o2_9,5	I	Cl	szary	1/0	+	30,5%	29,8%	85,3%	55,5%	0,01	0,99	148							
IV	o3_6,0	Iπ	Cl	szary	1/0	+	18,3%	17,8%		35,0%	0,01	0,99	125							
IV	o4_7,0	I	Cl	szary	1/0	+	25,9%	24,4%		50,0%	0,03	0,97	113							
V	o3_9,0	Pπ	siSa	beżowy		-	26,9%									1,22E-05			2,66	

UWAGA: * próbka namaczana