

Nr pom.	Pomieszczenie	Pow.	Wys.	Kub.	Straty ciepła OZC	Temp. wew.	Uwagi
-	-	m2	m	m3	W	°C	-
<b>PIWNICA</b>							
-1/PW/01	MAGAZYN	32,81	3	85,00	1033	20,00	
-1/PW/02	ROZDZ. C.O.	13,95	3	36,10	411	20,00	
-1/PW/03	P.T.	23,43	3	60,70	774	20,00	
-1/PW/04	MAGAZYN	108,71	3	281,60	3310	20,00	
-1/PW/05	PP	8,59	3	22,20	184	20,00	
-1/PW/06	MAGAZYN	34,63	3	89,70	626	20,00	
-1/PW/07	WC	9,31	3	24,10	380	24,00	
-1/PW/08	BIURO MAG	24,59	3	63,70	761	20,00	
-1/PW/09	POM. SOC.	14,26	3	36,90	344	20,00	
-1/PW/10	SZATNIA	26,33	3	68,20	1186	24,00	
-1/PW/11	SANIT.	13,96	3	36,20	326	20,00	
-1/PW/12	SANIT.	14,85	3	38,50	602	24,00	
-1/PW/13	SANIT.	26,28	3	68,10	727	20,00	
-1/PW/14	P.T.	40,77	3	105,60	1384	20,00	
-1/PW/15	P.T.	6,22	3	16,10	170	20,00	
-1/PW/16	SZATNIA	17,52	3	45,40	757	24,00	
-1/PW/17	P.SANIT.	7,16	3	18,50	185	20,00	
-1/PW/18	P.SANIT.	7,06	3	18,30	127	20,00	
-1/PW/19	SZATNIA	17,61	3	45,60	741	24,00	
-1/PW/20	SZATNIA	20,01	3	51,80	792	24,00	
-1/PW/21	SANIT	7,21	3	18,70	292	24,00	
-1/PW/22	P.SANIT	7,21	3	18,70	296	24,00	
-1/PW/23	SZATNIA	19,90	3	51,50	947	24,00	
-1/PW/24	P.T.	5,61	3	14,50	76	20,00	
-1/PW/25	ROZDZ.GŁ.	12,55	3	32,50	355	20,00	
-1/PW/26	P. BAT	12,99	3	33,70	359	20,00	
-1/PW/27	MAG.PT	26,76	3	69,30	778	20,00	
-1/PW/28	MAG./PT	13,15	3	34,10	357	20,00	
-1/PW/29	Węzeł	82,12	3	212,90	3175	20,00	
-1/PW/30	P.T.	21,09	3	54,60	552	20,00	
-1/PW/31	MAG/PT	46,57	3	120,70	1377	20,00	
-1/PW/32	PT.SPREŻ.	17,13	3	44,40	623	20,00	
-1/PW/33	PT.GAZ.MED	12,83	3	33,20	371	20,00	
-1/PW/34	PT.PRÓŻNIA	10,23	3	26,50	325	20,00	
-1/PW/35	PRZEDS.	61,65	3	159,70	920	20,00	
-1/PW/36	Korytarz	124,92	3	323,50	2506	20,00	
-1/PW/37	Korytarz	49,25	3	127,60	741	20,00	
-1/PW/38	Korytarz	82,72	3	214,20	1154	20,00	
<b>PARTER</b>							
00/IP/01	GAB KONSUL	13,24	3	39,60	794	24,00	
00/IP/02	Łazienka z oknem	5,97	3	17,80	638	24,00	
00/IP/03	PP	5,98	3	17,90	-94	20,00	
00/IP/05	KTG	14,08	3	42,10	734	24,00	
00/IP/06	G KONSUL	13,47	3	40,30	725	24,00	
00/IP/07	Łazienka z oknem	6,15	3	18,40	614	24,00	
00/IP/08	Łazienka bez okna	6,15	3	18,40	71	24,00	
00/IP/09	GAB ZAB OST	28,98	3	86,80	1601	24,00	
00/IP/10	POCZEK	45,08	3	134,80	2343	20,00	
00/IP/11	MAG	14,00	3	41,90	593	20,00	
00/IP/12	MAG BR	13,18	3	39,40	758	20,00	
00/IP/13	P KONS	11,64	3	34,80	1056	24,00	
00/IP/14	14+15	22,53	3	67,40	1505	24,00	
00/IP/16	WC	10,82	3	32,40	746	24,00	
00/IP/17	WC	11,69	3	35,10	704	24,00	
00/IP/18	Łazienka z oknem	11,84	3	35,40	1100	24,00	
00/IP/19	G KONSUL	11,55	3	34,50	773	24,00	
00/IP/20	P ODDZ	11,75	3	35,10	506	20,00	
00/IP/21	P SOC	12,26	3	36,70	529	20,00	
00/IP/22	Łazienka z oknem	4,92	3	14,70	615	24,00	
00/IP/23	WC	5,00	3	14,90	111	24,00	
00/IP/24	G KONSUL	11,45	3	34,20	745	24,00	
00/IP/25	Korytarz	91,57	3	273,80	-400	20,00	
00/PW/01	PT	5,87	3	17,60	17	20,00	
00/PW/02	Przedpokój	9,49	3	28,40	1078	20,00	
00/PW/03	Korytarz	38,90	3	116,30	146	20,00	
00/PW/04	S. KONSUL	14,67	3	43,90	812	24,00	
CHD 01	P.SOC.PAC.	21,21	3	63,40	1236	20,00	
CHD 2	Pokój	5,85	3	17,50	507	20,00	
CHD 3	WC	5,22	3	15,60	177	24,00	
CHD 4	P. BAD.	10,97	3	32,80	556	20,00	
CHD 5	ZAPLECZE	8,65	3	25,90	730	20,00	
CHD 6	P. PIEL.	7,72	3	23,10	30	20,00	
CHD 7	MAG	9,63	3	28,80	366	20,00	
CHD 8	Pokój	3,99	3	11,90	66	20,00	

CHD 9	Przedpokój	2,43	3	7,30	510	20,00	
CHD 10	KOM.	62,00	3	185,40	168	20,00	
CHD 11	S.CHORYCH	96,55	3	288,70	4531	20,00	
CHD 12	WC	8,24	3	24,60	753	24,00	
CHD 13	MAG.BRUD.	4,08	3	12,20	-19	20,00	
PON 1	Przedpokój	5,38	3	16,10	857	20,00	
PON 2	Korytarz	102,08	3	305,20	153	20,00	
PON 03	POCZEK.	24,31	3	72,70	1135	20,00	
PON 4	WC	7,50	3	22,40	731	24,00	
PON 5	WC	6,37	3	19,00	647	24,00	
PON 6	WC	6,51	3	19,50	101	24,00	
PON 7	WC	5,78	3	17,30	268	24,00	
PON 8	WC	5,59	3	16,70	318	24,00	
PON 9	MAG BRUD	4,26	3	13,00	144	20,00	
PON 10	Pokój	3,72	3	11,10	69	20,00	
PON 11	Przedpokój	2,53	3	7,60	611	20,00	
PON 12	GAB. RADIO.	13,49	3	40,30	786	20,00	
PON 13	GAB. CH. SUT.	13,05	3	39,00	585	20,00	
PON 14	GAB. CHIR.	12,96	3	38,80	587	20,00	
PON 15	GAB. OG.	12,96	3	38,70	583	20,00	
PON 16	GAB. OG.	12,97	3	38,80	582	20,00	
PON 17	ZAPŁ. REJ.	12,42	3	37,10	565	20,00	
PON 18	REJ.	26,52	3	79,30	1228	20,00	
PON 19	GAB. CHEM	12,96	3	38,80	568	20,00	
PON 20	GAB CHEM	13,09	3	39,10	585	20,00	
PON 21	GAB CHEM	12,85	3	38,40	585	20,00	
PON 22	KONSYL	12,90	3	38,60	589	20,00	
PON 23	SOC	10,87	3	32,50	302	20,00	
PON 24	Pokój oddzielony	11,18	3	33,40	560	20,00	
PON 25	SEKR	11,41	3	34,10	563	20,00	
PON 26	GAB ORD	11,29	3	33,70	561	20,00	
SRE 1	SALA REHA.	42,21	3	126,20	1882	20,00	
PIETRO 1							
01/OG/01	Kuchnia z oknem gaz	11,43	3	34,2	607	20	
01/OG/02	Kuchnia z oknem gaz	11,49	3	34,4	554	20	
01/OG/03	ŚLUZA	5,34	3	16	-18	20	
01/OG/04	łazienka z oknem	4,63	3	13,8	694	24	
01/OG/05	IZOL	12,08	3	36,1	544	20	
01/OG/06	IZOL	11,88	3	35,5	524	20	
01/OG/07	łazienka z oknem	4,63	3	13,8	463	24	
01/OG/08	ŚLUZA	5,34	3	16	-11	20	
01/OG/09	PP	5,58	3	16,7	155	20	
01/OG/10	Pokój	23,95	3	71,6	1368	20	
01/OG/11	łazienka bez okna	2,99	3	8,9	124	24	
01/OG/12	Pokój	23,82	3	71,2	1141	20	
01/OG/13	łazienka bez okna	2,95	3	8,8	124	24	
01/OG/14	MAG	13,84	3	41,4	565	20	
01/OG/15	MAG	12,5	3	37,4	560	20	
01/OG/16	S. WZMOŻ. NADZ.	28,09	3	84	1224	20	
01/OG/17	KTG	13,49	3	40,3	590	20	
01/OG/18	PUNKT PIEL	27,73	3	82,9	1251	20	
01/OG/19	P POBR	6,7	3	20	548	20	
01/OG/20	P POBR	6,91	3	20,6	16	20	
01/OG/21	S WZM NADZ	27,55	3	82,4	1193	20	
01/OG/22	Pokój	23,83	3	71,3	1121	20	
01/OG/23	łazienka bez okna	2,79	3	8,3	125	24	
01/OG/24	Pokój	23,87	3	71,4	1175	20	
01/OG/25	łazienka bez okna	2,93	3	8,8	122	24	
01/OG/26	Pokój	13,07	3	39,1	588	20	
01/OG/27	P LEK DYŻ	10,46	3	31,3	510	20	
01/OG/28	łazienka bez okna	2,96	3	8,8	98	24	
01/OG/29	Pokój	24,16	3	72,2	1146	20	
01/OG/30	łazienka bez okna	2,95	3	8,8	97	24	
01/OG/31	Pokój	24,07	3	72	1369	20	
01/OG/32	łazienka bez okna	2,95	3	8,8	124	24	
01/OG/33	WC	5,86	3	17,8	194	20	
01/OG/34	WC	11,12	3	33,2	337	20	
01/OG/35	łazienka z oknem	10,82	3	32,4	802	24	
01/OG/36	Pokój	12,61	3	37,7	460	20	
01/OG/37	łazienka z oknem	4,6	3	13,8	644	24	
01/OG/38	łazienka bez okna	5,34	3	16	118	24	
01/OG/39	WC	5,34	3	16	-29	20	
01/OG/40	łazienka z oknem	4,6	3	13,8	678	24	
01/OG/41	Pokój	12,71	3	38	554	20	
01/OG/42	USG	22,52	3	67,3	1191	20	
01/OG/43	P ODDZ	12,11	3	36,2	589	20	
01/OG/44	Pokój	10,73	3	32,1	537	20	
01/OG/45	USG	13,64	3	40,8	565	20	
01/OG/46	P BADAN	14,36	3	42,9	922	24	

01/OG/47	DYŻ LEK	12,18	3	36,4	537	20	
01/OG/48	WC	1,83	3	5,5	-22	20	
01/OG/49	Pokój	24,74	3	74	1415	22	
01/OG/50	łazienka bez okna	2,98	3	8,9	62	24	
01/OG/51	Pokój	24,61	3	73,6	1414	22	
01/OG/52	łazienka bez okna	3,03	3	9,1	42	24	
01/OG/53	Pokój	25,61	3	76,6	1427	22	
01/OG/54	łazienka bez okna	2,92	3	8,7	34	24	
01/OG/55	Pokój	25,42	3	76	1425	22	
01/OG/56	łazienka bez okna	3	3	9	45	24	
01/OG/57	Pokój	25,52	3	76,3	1618	22	
01/OG/58	łazienka bez okna	3,03	3	9,1	41	24	
01/OG/59	Pokój	12,88	3	38,5	755	20	
01/OG/60	łazienka z oknem	5,13	3	15,3	676	24	
01/OG/61	łazienka bez okna	5,21	3	15,6	140	24	
01/OG/62	Pokój	11,56	3	34,6	486	20	
01/OG/63	Pokój	11,75	3	35,1	469	20	
01/OG/64	łazienka z oknem	4,97	3	14,9	635	24	
01/OG/65	łazienka bez okna	5,06	3	15,1	122	24	
01/OG/66	Pokój	12,36	3	36,9	552	20	
01/OG/67	Pokój	12,26	3	36,7	474	20	
01/OG/68	łazienka z oknem	5,02	3	15	661	24	
01/OG/69	łazienka bez okna	5,11	3	15,3	130	24	
01/OG/70	Pokój	12,27	3	36,7	482	20	
01/OG/71	BRUD	5,7	3	17,1	-21	20	
01/OG/72	łazienka z oknem	5,62	3	16,8	719	24	
01/OG/73	POK ORD	11,08	3	33,1	508	20	
01/OG/74	PT	5,48	3	16,4	21	20	
01/OG/75	Korytarz	49,01	3	146,5	324	20	
01/OG/76	Korytarz	91,79	3	274,5	1164	20	
01/OG/77	Korytarz	95,97	3	286,9	995	20	
01/OG/78	Korytarz	84,16	3	251,6	55	20	
01/OG/79	Korytarz	8,66	3	25,9	590	20	
PIETRO 2							
02/OU/01	Kuchnia z oknem gaz	11,64	3	34,8	630	20	
02/OU/02	Kuchnia z oknem gaz	11,52	3	34,4	555	20	
02/OU/03	BRUD	5,37	3	16	-11	20	
02/OU/04	łazienka z oknem	4,64	3	13,9	694	24	
02/OU/05	Pokój	12,12	3	36,2	476	20	
02/OU/06	Pokój	11,92	3	35,6	820	24	
02/OU/07	łazienka z oknem	4,64	3	13,9	420	24	
02/OU/08	SLUZA	5,37	3	16	-56		
02/OU/09	PP	5,59	3	16,7	156	20	
02/OU/10	Pokój	23,99	3	71,7	1500	22	
02/OU/11	łazienka bez okna	3	3	9	40	24	
02/OU/12	Pokój	23,85	3	71,3	1290	22	
02/OU/13	łazienka bez okna	2,96	3	8,9	67	24	
02/OU/14	DYZ LEK	13,85	3	41,4	510	20	
02/OU/15	GAB ZAB CZ	12,49	3	37,4	812	24	
02/OU/16	MAG BR	8,58	3	25,7	-76	20	
02/OU/17	łazienka z oknem	4,9	3	14,6	652	24	
02/OU/18	G ZAB BR	13,69	3	40,9	819	24	
02/OU/19	P S PIEL	13,47	3	40,3	568	20	
02/OU/20	PUNKT PIEL	27,51	3	82,3	1167	20	
02/OU/21	G ZAB	14,22	3	42,5	855	24	
02/OU/22	S WZMOZ NADZ	27,51	3	82,3	1599	24	
02/OU/23	M SPRZ	13,85	3	41,4	467	20	
02/OU/24	P BAD	13,83	3	41,4	793	24	
02/OU/25	Pokój	23,46	3	70,1	1289	22	
02/OU/26	łazienka bez okna	2,88	3	8,6	39	24	
02/OU/27	MAG	13,1	3	39,2	588	20	
02/OU/28	P LEK DYZ	10,48	3	31,3	510	20	
02/OU/29	łazienka bez okna	2,97	3	8,9	98	24	
02/OU/30	Pokój	24,19	3	72,3	1295	22	
02/OU/31	łazienka bez okna	2,96	3	8,9	40	24	
02/OU/32	Pokój	24,1	3	72,1	1501	22	
02/OU/33	łazienka bez okna	2,96	3	8,9	40	24	
02/OU/34	WC	5,86	3	17,5	302	24	
02/OU/35	WC	11,12	3	33,2	563	24	
02/OU/36	MAG CZ	10,82	3	32,4	499	20	
02/OU/37	Pokój	12,62	3	37,7	527	20	
02/OU/38	łazienka z oknem	4,62	3	13,8	644	24	
02/OU/39	łazienka bez okna	5,34	3	16	110	24	
02/OU/40	WC	5,34	3	16	118	24	
02/OU/41	łazienka z oknem	4,62	3	13,8	644	24	
02/OU/42	Pokój	12,72	3	38	459	20	
02/OU/43	łazienka z oknem	10,52	3	31,5	796	24	
02/OU/44	POK ORD	12,52	3	37,6	543	20	

02/OU/45	P ODDZ	11,32	3	33,8	559	20	
02/OU/46	SEKR	10,54	3	31,5	540	20	
02/OU/47	Korytarz	92,28	3	275,9	939	20	
02/OU/48	Korytarz	95,17	3	284,6	661	20	
02/PW/01	PT	5,49	3	16,4	21	20	
02/PW/02	Korytarz	49,07	3	146,7	324	20	
02/SZ/01	POCZEK	12,69	3	37,9	562	20	
02/SZ/02	P PORZ	3,56	3	10,7	-26	20	
02/SZ/03	PRZ LEK	3,56	3	10,7	103	24	
02/SZ/04	STEROW	7,46	3	22,3	478	20	
02/SZ/05	PRAC ESWL	26,77	3	80	1703	24	
02/SZ/06	PRZYG PAC	9,84	3	29,4	-28	20	
02/SZ/07	P HIG	3,99	3	11,9	525	20	
02/SZ/08	PRZYG PAC	9,84	3	29,4	-33	20	
02/SZ/09	P HIG	3,99	3	11,9	525	20	
02/SZ/10	S ENDOSK	27,27	3	81,5	1595	24	
02/SZ/11	PRZ LEK	3,62	3	10,8	103	24	
02/SZ/12	MYC END	9,96	3	29,8	493	20	
02/SZ/13	PRZYG PAC	10,75	3	32,2	-29	20	
02/SZ/14	P HIG	4,36	3	13	535	20	
02/SZ/15	S ZABIEG	27,02	3	80,8	1591	24	
02/SZ/16	PRZYG LEK	3,49	3	10,4	101	24	
02/SZ/17	BRUDOW	10,97	3	32,8	682	20	
02/SZ/18	P SOC	12,47	3	37,3	891	20	
02/SZ/19	MAG	10,85	3	32,5	296	16	
02/SZ/20	POK OPISU	11,56	3	34,6	627	20	
02/SZ/21	WC	5,16	3	15,4	102	24	
02/SZ/22	łazienka z oknem	5,08	3	15,2	618	24	
02/SZ/23	S WYBUDZ	24,42	3	73	1508	24	
02/SZ/24	WC	6,71	3	20,1	103	24	
02/SZ/25	łazienka z oknem	4,61	3	13,8	608	24	
02/SZ/26	PR URODYN	11,66	3	34,9	760	24	
02/SZ/27	GAB LEK	11,06	3	33,1	512	20	
02/SZ/28	GAB ZAB	12,88	3	38,5	581	20	
02/SZ/29	GAB LEK	10,47	3	31,3	563	20	
02/SZ/30	Korytarz	33,28	3	99,5	-109	20	
02/SZ/31	Korytarz	58	3	173,4	480	20	
PIETRO 3							
03/ON/01	Kuchnia z oknem gaz	11,61	3	34,7	621	20	
03/ON/02	Kuchnia z oknem gaz	11,49	3	34,4	592	20	
03/ON/03	ŚLUZA	5,34	3	16	-24	20	
03/ON/04	łazienka z oknem	4,63	3	13,8	484	20	
03/ON/05	IZOL	12,08	3	36,1	850	24	
03/ON/06	IZOL	11,88	3	35,5	827	24	
03/ON/07	łazienka z oknem	4,63	3	13,8	278	20	
03/ON/08	ŚLUZA	5,34	3	16	-24	20	
03/ON/09	PP	5,58	3	16,7	206	20	
03/ON/10	Pokój	23,96	3	71,6	1541	22	
03/ON/11	łazienka bez okna	2,99	3	8,9	7	20	
03/ON/12	Pokój	23,82	3	71,2	1331	22	
03/ON/13	łazienka bez okna	2,95	3	8,8	2	20	
03/ON/14	MAG	10,22	3	30,5	515	20	
03/ON/15	łazienka bez okna	3,16	3	9,4	7	20	
03/ON/16	P BADAN	12,22	3	36,5	826	24	
03/ON/17	P OBSŁ BAD KLIN	28,09	3	84	1222	20	
03/ON/18	P S PIEL	13,69	3	40,9	608	20	
03/ON/19	PUNKT PIEL	27,73	3	82,9	1295	20	
03/ON/20	P PRZYG	13,72	3	41	575	20	
03/ON/21	GAB DIAG ZAB	27,55	3	82,4	1628	24	
03/ON/22	Pokój	24,13	3	72,1	1336	22	
03/ON/23	łazienka bez okna	2,89	3	8,6	-16	20	
03/ON/24	Pokój	23,43	3	70	1585	24	
03/ON/25	łazienka bez okna	2,87	3	8,6	-49	20	
03/ON/26	SEKR	13,07	3	39,1	583	20	
03/ON/27	P ORD	13,88	3	41,5	603	20	
03/ON/28	DYZ LEK	28,35	3	84,8	1306	20	
03/ON/29	S SEM	28,31	3	84,7	1503	20	
03/ON/30	WC	5,86	3	17,5	200	20	
03/ON/31	WC	8,53	3	25,5	363	20	
03/ON/32	łazienka bez okna	3,24	3	9,7	130	24	
03/ON/33	P LEK DYZ	10,51	3	31,4	539	20	
03/ON/34	SEKR	22,36	3	66,9	1230	20	
03/ON/35	ŚLUZA	5,32	3	15,9	-33	20	
03/ON/36	łazienka z oknem	4,6	3	13,8	489	20	
03/ON/37	IZOL	12,69	3	38	864	24	
03/ON/38	łazienka z oknem	10,52	3	31,5	707	24	
03/ON/39	ŚLUZA	5,35	3	16	-24	20	
03/ON/40	łazienka z oknem	4,63	3	13,8	491	20	

03/ON/41	IZOL	12,49	3	37,3	893	24	
03/ON/42	P ODDZ	10,33	3	30,9	481	20	
03/ON/43	P BAD	13,25	3	39,6	782	24	
03/ON/44	GAB ZAB	13,95	3	41,7	823	24	
03/ON/45	MAG	13,95	3	41,7	530	20	
03/ON/46	Pokój	23,9	3	73,1	1524	22	
03/ON/47	Łazienka bez okna	2,98	3	9,1	30	20	
03/ON/48	Pokój	23,85	3	73	1522	22	
03/ON/49	Łazienka bez okna	3,03	3	9,3	36	20	
03/ON/50	Pokój	24,82	3	75,9	1542	22	
03/ON/51	Łazienka bez okna	2,94	3	9	29	20	
03/ON/52	Pokój	24,71	3	75,6	1540	22	
03/ON/53	Łazienka bez okna	3,06	3	9,4	35	20	
03/ON/54	Pokój	24,67	3	75,5	1737	22	
03/ON/55	Łazienka bez okna	3,03	3	9,3	30	20	
03/ON/56	Pokój	12,87	3	39,4	958	20	
03/ON/57	Łazienka z oknem	5,11	3	15,7	586	20	
03/ON/58	Łazienka bez okna	5,19	3	15,9	66	20	
03/ON/59	Pokój	11,55	3	35,3	678	20	
03/ON/60	Łazienka z oknem	16,72	3	51,2	1284	20	
03/ON/62	Łazienka bez okna	5,05	3	15,5	49	20	
03/ON/63	Pokój	12,34	3	37,8	673	20	
03/ON/64	Pokój	12,24	3	37,5	670	20	
03/ON/65	Łazienka z oknem	5,02	3	15,4	567	20	
03/ON/66	Łazienka bez okna	5,11	3	15,6	50	20	
03/ON/67	Pokój	12,27	3	36,7	564	20	
03/ON/68	SWIETLICA	23,23	3	69,4	1275	20	
03/ON/69	PT	5,49	3	16,4	15	20	
03/ON/70	Korytarz	49,03	3	146,6	519	20	
03/ON/71	Korytarz	92,35	3	276,1	1141	20	
03/ON/72	Korytarz	45,46	3	135,9	-184	20	
03/ON/73	Korytarz	48,28	3	144,4	901	20	
03/ON/74	Korytarz	93,33	3	284,2	1934	20	
PIETRO 4							
04/CD/01	P ODDZ	11,2	3	34,3	697	20	
04/CD/02	SEKR	21,94	3	67,1	1401	20	
04/CD/03	POK SOC	11,8	3	36,1	671	20	
04/CD/04	WC	6,59	3	20,2	597	20	
04/CD/05	WC	7	3	21,4	72	20	
04/CD/06	WC	7	3	21,4	403	20	
04/CD/07	PP	5,44	3	16,6	229	20	
04/CD/08	MAG BRUD	3,36	3	10,3	128	20	
04/CD/09	MAG CZ	10,86	3	33,2	795	20	
04/CD/10	P KONSYL	13,73	3	42	642	20	
04/CD/11	GAB KONSYL	14,24	3	43,6	907	24	
04/CD/12	GAB KONSYL	14,01	3	42,9	844	24	
04/CD/13	GAB KONSYL	14,24	3	43,6	866	24	
04/CD/14	GAB KONSYL	14	3	42,8	903	24	
04/CD/15	POCZEKALNIA	28,85	3	88,3	1467	20	
04/CD/16	P BADAN	14,18	3	43,4	720	20	
04/CD/17	PUNKT PRZYJ	28,63	3	87,6	1515	20	
04/CD/18	P BADAN	14,18	3	43,4	728	20	
04/CD/19	MAG	7,1	3	21,7	72	20	
04/CD/20	WC	6,64	3	20,3	613	20	
04/CD/21	S PODAN	133,1	3	407,3	6314	20	
04/CD/22	PUNKT PIEL	13,82	3	42,3	1320	20	
04/CD/23	WC	6,24	3	19,1	703	20	
04/CD/24	BRUD	6,74	3	20,6	181	20	
04/CD/25	PP	5,32	3	16,3	244	20	
04/CD/26	WC	6,55	3	20	273	20	
04/CD/27	S PODAN	54,78	3	167,6	3116	20	
04/CD/28	PUNKT PIEL	7,34	3	22,5	634	20	
04/CD/29	S PODAN	23,32	3	71,4	1372	20	
04/CD/30	G ZAB	22,34	3	68,4	1589	24	
04/CD/31	Korytarz	61,3	3	187,6	1303	20	
04/CD/32	Korytarz	27,29	3	83,5	344	20	
04/CD/33	Korytarz	92,55	3	283,2	1769	20	
04/PW/01	P T TELETECH	5,58	3	17,1	65	20	
04/PW/02	Klep	9,3	3	28,4	275	20	
04/PW/03	Pokój	68,49	3	209,6	1202	20	
04/PW/04	WC	4,54	3	13,9	51	20	
04/PW/05	Pokój	4,49	3	13,7	229	20	
04/PW/06	ZAPLECZE	8,79	3	26,9	301	20	
04/PW/07	BAR	7,15	3	21,9	110	20	
04/PW/09	Korytarz	37,39	3	114,4	410	20	

KL1	Klatka schodowa	108,55	3	318,6	3183	20	
KL2	Klatka schodowa	89,93	3	263,6	3920	20	
KL3	Klatka schodowa	105,63	3	310,7	5408	20	
KL4	Klatka schodowa	100,94	3	298	5416	20	