

L.p.	Opis	Moc jednostkowa	Ilość	Moc zainstalowana	Wsp. jednoczesności	Moc szczytowa	Wsp. mocy		Prąd szczytowy	Moc bierna	Moc pozorna
		P	n	Pi	kj	Po	cos φ	tg φ	Io	Q	S
		[kW]	[szt]	[kW]		[kW]			[A]	[kVar]	[kVA]
	TECHNOLOGIA										
1	agregat wody lodowej	289,00	2,0	578,00	0,70	404,60	0,88	0,54	664,41	218,38	459,77
2	pompa wody lodowej	24,10	2,0	48,20	0,70	33,74	0,90	0,48	54,17	16,34	37,49
3	pompa drycoolera	11,50	2,0	23,00	0,70	16,10	0,85	0,62	27,37	9,98	18,94
4	drycoller	24,50	2,0	49,00	0,70	34,30	0,89	0,51	55,69	17,57	38,54
	SUMA			698,20	0,70	488,74	0,88	0,54	801,54	262,27	554,66
	MOC BATERII									69,11	
	PO KOMPENSACJI			698,20		488,74	0,93	0,40	759,43	193,16	525,53